

CATALOG NUMBER

ECHBK

electriCenter
ACCESSORIES

Horn Bypass Kit



Same As:
■ HBPU ■ DHB

INSTALLATION INSTRUCTIONS

⚠ DANGER
Hazardous Voltage.
Will cause death, serious injury or substantial property damage.
Turn off power supplying this equipment before working inside.


Note: This instruction outlines the recommended installation procedure.

Install device in accordance with local and National Electrical Code requirements. Refer to wiring diagram label for specific details concerning application.

SAFETY INSTRUCTIONS

1. Turn off and lock off the power supplying the device before working inside.
2. Remove the (4) #10 nuts and washers. Retain for reassembly in Step 4.
3. Position bypass horns as shown in Figure 1.
4. Reinstall washers and nuts removed in Step 2.
5. Tighten nuts to 24-30 lb.-in.

FIGURE 1



© 2004 Copyright Siemens Energy & Automation, Inc. 4810493 Rev.A
Siemens Energy & Automation, Inc. Alpharetta, Georgia U.S.A. Assembled in Mexico

PRINT COLOR: BLACK
CUT SIZE: 4.25 x 7.25
MATERIAL: 70# WHITE BOND PAPER

| | | |
|---------------------------------------------------------------------------------|----------------------------------|---------------------------------|
| DESIGN RESPONSIBILITY LOCATION: SEA-ITESA2 | | |
| PRINT DISTRIBUTION | | |
| ECN COPIES MUST BE ISSUED TO ALL CHECKED LOCATIONS FOR APPROVAL PRIOR TO CHANGE | | |
| <input type="checkbox"/> SFA-TUC | <input type="checkbox"/> SFA-DRM | <input type="checkbox"/> McPHFR |
| <input type="checkbox"/> SEA-NOR | <input type="checkbox"/> DUR-LEB | <input type="checkbox"/> CHOICE |
| <input type="checkbox"/> SFA-MIA | <input type="checkbox"/> DUR-HOU | <input type="checkbox"/> IC-ASY |
| <input type="checkbox"/> SEA-BEL | <input type="checkbox"/> SEA-EL | <input type="checkbox"/> * |

| | | | | | | | | | | | | | |
|-------------|-----------|-----|----------|-----------------------------------|------------------------------------------------------------------------------------------------------|-----|-------------------------------------------------------------------------------------------------------------|----------|----------|--------------------------|----------------------|----------|-------------------|
| | | | | | UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES | | -CONFIDENTIAL- PROPERTY OF Siemens Energy & Automation, Inc. Residential Products Division | | | | | | |
| | | | | | TOLERANCES: .XX ±.25 .XXX HOLE DIAMETER ±.005 ANGULAR UNDIMENSIONED 90° ANGLES ±0°30' | | | | | INSTRUCTION SHEET | | | |
| | | | | | DWN | KAM | DATE | 10/26/04 | SIZE | | | | ISSUE RELEASE NO. |
| | | | | | CHK | | DATE | | B | 03-061-24 | 4810493 | B | |
| | | | | | APVD | | DATE | | SCALE | 1:1 | DO NOT SCALE DRAWING | SHEET | 1 OF 1 |
| 1st ARTICLE | EDR NO. | REV | DATE | DESCRIPTION | BY | | | | | | | | |
| | 05-043-11 | B | 3/3/06 | TRANSFER DESIGN CONTROL TO ITESA2 | KAM | | | | | | | | |
| | 03-061-24 | A | 10/26/04 | ISSUE | KAM | | | | | | | | |