

The image features a close-up, low-angle view of a large industrial turbine, likely a gas turbine. The turbine's components are painted in a vibrant red color. The top of the turbine shows several concentric, curved blades or stator vanes, creating a sense of depth and rotation. The background is a bright, clear blue sky, suggesting an outdoor industrial setting. In the top left corner, the Siemens logo is displayed in white text on a black rectangular background.

SIEMENS

www.siemens.com/energy

GEAFOL –
certified quality

Answers for energy.

First among supposed equals

If you're going to compare cast-resin transformers, it's a good idea to take a very close look. Because as always, you can expect something exceptional from the inventor of the cast-resin transformer. Tests passed and certificates received with flying colors have been highlighting the excellence of our GEAFOLE transformers with aluminum-foil technology since 1966.

More than 100,000 units worldwide are in operation today, in some cases under extremely harsh conditions such as:

- *Ambient temperatures of ± 60 °C*
- *Aggressive, salt-laden atmospheres*
- *Great mechanical stress, for example on ships, cranes or nacelles of wind power plants*



GEAFOLE – better than the standard right from the start
When you pioneer new technology, you can only win customer confidence through strict testing. Well aware of this, we've been putting the GEAFOLE through the paces right from the start – with very convincing results. We've always made sure that we didn't simply meet the requirements of the applicable standards, but that we far exceeded them in many cases.

And as can be expected with pioneering technology, there weren't even any national or international tests for some criteria when our GEAFOLE came on the market. That's why we conducted fire tests on GEAFOLE transformers in conjunction with the Allianz Test Centers long before a corresponding standard was introduced.





GEAFOL – more than standard

Unless other test conditions have been agreed contractually, we always subject every transformer to routine testing in line with IEC 60076-11. That means you can be sure that your GEAFOL transformer was tested in accordance with the valid standards and has met the requirements. And thanks to its versatility, GEAFOL can be used in an especially wide range of applications. In some cases this makes special testing necessary – testing which goes beyond the type tests or the special testing stipulated in the standards – in order to guarantee absolute operational safety. One example of such testing is for nuclear power plants.


GEAFOL – one for all

Now, however, we have undertaken something completely new: one and the same GEAFOL has passed all routine, type and special tests defined for dry transformers.

The special thing about this is: Because in some cases, the tests were performed under conditions that were considerably more rigorous in comparison to the standard. The result clearly shows that the GEAFOL transformer offers you enough reserves for long, successful operation under all conditions.



A new standard is setting new standards – just like GEAFOl



Magnetic flux density, measured 0.8 m above the transformer base

Limit values comply with 26. BImSchV:
Electrical field strength 5 kV/m (at 50 Hz)
Magnetic flux density 100 µT (at 50 Hz)

Electrical fields: Simple shielding by means of housing or accommodation in cells

Magnetic fields: Field density behaves proportionally $1/a^2$ to $1/a^3$ (a = distance)
The magnetic flux density decreases very rapidly as the distance increases

Important:

Leakage fields of the US busbar system have great influence on the total field. Options should therefore be specified in the contract.

In the course of harmonizing standards, the current IEC 60076-11 or EN 60076-11 and VDE 0532-76-11 replaced the old VDE 0532-726 or EN 0532-726. Though the routine, special and type tests were not changed in the reorganization, the test requirements were specified more clearly in the newer standards and have been adapted to IEC 60076-3.

Tailored testing

Along with routine tests that every transformer must pass, there are also type and special tests which must be agreed upon separately when an order is placed. In addition to tests to the finished product, precisely defined interim tests are performed for selected process sections and incoming goods inspections on the raw materials used.

Tailored performance

Here Siemens once again pioneered the way with GEAFOl and demonstrated how quality is achieved in actual practice. **One and the same** GEAFOl transformer has passed all defined routine, type and special tests, along with additional tests with flying colors.





Routine tests

- Measurement of winding resistance (IEC 60076-11)
- Measurement of voltage ratio and check of phase displacement (IEC 60076-11)
- Measurement of short-circuit impedance and load loss (IEC 60076-11)
- Measurement of no-load loss and current (IEC 60076-11)
- Separate-source AC withstand voltage test (IEC 60076-11)
- Induced AC withstand voltage test (IEC 60076-11)
- Partial discharge measurement (IEC 60076-11)

Type tests

- Lightning impulse test (IEC 60076-11)
- Temperature-rise test (IEC 60076-11)

Special tests

- Measurement of sound level (IEC 60076-11)
- Verification of environmental class (IEC 60076-11)
- Verification of climatic class (IEC 60076-11)
- Fire behavior test (destructive test, IEC 60076-11)
- Magnetic field measurement (IEEE 644-1994 and IEC 61786-1998)

Performance data confirmed by testing and disclosed by the manufacturer

Rated power	1,500 kVA
Number of phases	3
Rated voltage of the high-voltage winding (primary winding)	11 kV / 6.6 kV
Rated voltage of the low-voltage winding (secondary winding)	400 V
Rated frequency	50 Hz
Vector group	Dyn11
Impedance voltage	7.5%
Insulation level of the high-voltage winding (primary winding)	LI 75 AC 28
Insulation level of the low-voltage winding (secondary winding)	AC 3
Cooling type	AN

The tested model was a transformer that can be reconnected for 11 kV to 6.6 kV at a constant output.

Signed and sealed – quality à la GEA FOL



Accredited test labs, renowned testers

Some of the tests were performed in certified test labs at our manufacturing sites, and others at the CESI in Milan, Italy. Because the transformer was delivered in a special housing, tests were also performed using the housing insofar as it could have influenced measurements.

CE marking

Cast-resin transformers are to be considered passive elements in accordance with IEC 60076-11. As stipulated by the COTREL specification, CE marking of power and distribution transformers with medium- and high-voltage windings is not permissible.

Red-hot test results

The standard specifies permissible limits for the fire test which may not be exceeded. These limits are coordinated with the geometries of the fire chamber and the test specimen. The coils of the GEA FOL transformer to be tested considerably exceeded the device dimensions described in the standard and thus almost reached the limit value for the test chamber, the GEA FOL transformer nevertheless remained far below the permissible maximum values allowed by the standard.

For us, this was a further milestone in the success story of the GEA FOL. At no time since the introduction of the standard for fire behavior have we tested a higher rating in the IEC test.

Naturally, the fire test is always a special test because it destroys the transformer. But it also serves to verify that operating GEA FOL cast-resin transformers in electrical facilities essentially creates no risks in any operating mode that intensify fire or produce toxic hazards exceeding the normal magnitude of house or industrial fires. So there were good reasons why GEA FOL transformers were classified in the highest fire class F1 according to IEC 60076-11.

Certified quality means even more safety and reliability

With CESI's certification and the more extensive analyses, Siemens again has verified that GEA FOL cast-resin transformers also exceed the highest requirements defined in the standard – an extra safety margin that you shouldn't be without.

Tests performed with housing attached	
Type of additional tests	with housing
Measurement of impedance voltage	■
Separate-source AC withstand voltage test	■
Induced AC withstand voltage test and partial discharge measurement	■
Measurement of load loss	■
Lightning impulse test	■
Temperature-rise test	■
Measurement of sound level	■
Verification of short-circuit withstand capability	■



Test performed as a function of the primary voltage			
Type of tests		6.6 kV	11 kV
Routine	Measurement of winding resistance	■	■
	Measurement of voltage ratio and check of vector group	■	■
	Measurement of impedance voltage and load loss	■	■
	Measurement of no-load loss and no-load current	■	■
	Separate-source AC withstand voltage test	■	■
	Induced AC withstand voltage test	■	■
	Partial discharge measurement	■	■
Type	Lightning impulse test	■	■
	Temperature-rise test	–	■
Special tests	Measurement of sound level	≧ 11 kV	■
	Verification of short-circuit withstand capability	■	■
	Verification of climatic class C2 (thermal shock)	■	■
	Verification of fire class F1 with check of gas emissions	≧ 11 kV	■
	Verification of environmental class E2	≧ 11 kV	■
	Electromagnetic compatibility measurement	≧ 11 kV	■

GEAFOL – in all circumstances



IEC Standard 60076-11 (HD 464 S1 1988) specifies environmental, climatic and fire classes for cast-resin transformers and their operating conditions.

GEAFOL transformers have also subjected their special classes to verification in this case. With Environmental Class **E2**, Climatic Class **C2** and Fire Class **F1**, they meet the highest requirements defined in each case and are equal to the hardest requirements.



Environmental Class E2 – E0	Climatic Class C2	Fire Class F1
		
<p>E0 The transformer operates in a clean, dry environment with no condensation or relevant environmental contamination.</p> <p>E1 The transformer operates in an environment with the occasional formation of condensate and negligible contamination.</p> <p>E2 The transformer is exposed to considerable condensate formation and heavy contamination or both.</p>	<p>C1 The transformer is not suitable for operation at temperatures under -5°C, but can be transported and stored at up to -25°C.</p> <p>C2 Storage, transport and operation of the transformer is possible at up to -25°C.</p>	<p>F0 The transformer operates in an environment with no fire hazards, which is why no measures are necessary to limit the risk of flammability.</p> <p>F1 The transformer is used in an environment where fire hazards exist; as a result, reduced risk of flammability is required. A transformer fire must be extinguished within certain specifications.</p>

48021101
Page 1

Type Test Certificate CESI

Type Test Certificate of Complete type tests

Apparatus Dry-type power transformer

Designation 40MVA-110kV
Rated power 1000 kVA, Rated voltage 110 kV, Rated frequency 50 Hz

Manufacturer SIEMENS Transformatore KB - Budapest - Hungary

Tested for SIEMENS Transformatore KB - Budapest - Hungary

Dates of tests From 15 October 11, 2009 to October 24, 2009

Tested by CESI S.p.A. - Milano - ITALY

The apparatus concerned is described with the description, drawings and photographs incorporated in the reference documents, identified in this certificate. See Annex referred to the series of proving tests in accordance with:

IEC 60076-11 (2006)

This Type Test Certificate has been issued by CESI following conformity with the ITC-Code.

The results are shown in the record of Proving Tests and the intelligence attached in the Test Reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity with the standards rests with the Manufacturer.

Only original reproductions of this Certificate, or reproductions of this page accompanied by the apparatus serial, are permitted without written permission from CESI.

No. of pages 1

Issue date November 17, 2009

Prepared Gino LABRIAZZORRE - V. Manzoni

Prepared L.P. Manegazza Virozzi

Verified L.P. Diot Prisco

Approved L.P. Spigolon Roberto

CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY

48021101
Page 1

Type Test Certificate CESI

Type Test Certificate of Special test to prove stability in climatic class C3, in environmental class E2 and in the behaviour test class F1

Apparatus Dry-type power transformer

Designation 40MVA-110kV
Rated power 1000 kVA, Rated voltage 110 kV, Rated frequency 50 Hz

Manufacturer SIEMENS Transformatore KB - Budapest - Hungary

Tested for SIEMENS Transformatore KB - Budapest - Hungary

Dates of tests From 15 October 15, 2009 to November 14, 2009

Tested by CESI S.p.A. - Milano - ITALY

The apparatus concerned is described with the description, drawings and photographs incorporated in the reference documents, identified in this certificate. See Annex referred to the series of proving tests in accordance with:

IEC 60076-11 (2006)

This Type Test Certificate has been issued by CESI in accordance with above mentioned standards.

The results are shown in the record of Proving Tests and the intelligence attached in the Test Reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the Manufacturer.

Only original reproductions of this Certificate, or reproductions of this page accompanied by any pages in which are used the indicated ratings of the apparatus serial, are permitted without written permission from CESI.

No. of pages 3

CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY

48021101
Page 1

Type Test Certificate CESI

Type Test Certificate of Short-circuit performance
Deductive performance

Apparatus Dry-type power transformer

Designation 40MVA-110kV
Rated power 1000 kVA, Rated voltage 110 kV, Rated frequency 50 Hz

Manufacturer SIEMENS Transformatore KB - Budapest - Hungary

Tested for SIEMENS Transformatore KB - Budapest - Hungary

Dates of tests From 15 October 15, 2009 to October 24, 2009

Tested by CESI S.p.A. - Milano - ITALY

The apparatus concerned is described with the description, drawings and photographs incorporated in the reference documents, identified in this certificate. See Annex referred to the series of proving tests in accordance with:

IEC 60076-11 (2006)

This Type Test Certificate has been issued by CESI following conformity with the ITC-Code.

The results are shown in the record of Proving Tests and the intelligence attached in the Test Reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the Manufacturer.

Only original reproductions of this Certificate, or reproductions of this page accompanied by any pages in which are used the indicated ratings of the apparatus serial, are permitted without written permission from CESI.

No. of pages 3

Issue date November 17, 2009

Prepared Gino LABRIAZZORRE - V. Manzoni

Prepared L.P. Manegazza Virozzi

Verified L.P. Diot Prisco

Approved L.P. Spigolon Roberto

CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY

48021101
Page 1

Type Test Certificate CESI

Type Test Certificate of Short-circuit performance
Deductive performance

Apparatus Dry-type power transformer

Designation 40MVA-110kV
Rated power 1000 kVA, Rated voltage 110 kV, Rated frequency 50 Hz

Manufacturer SIEMENS Transformatore KB - Budapest - Hungary

Tested for SIEMENS Transformatore KB - Budapest - Hungary

Dates of tests From 15 October 15, 2009 to October 24, 2009

Tested by CESI S.p.A. - Milano - ITALY

The apparatus concerned is described with the description, drawings and photographs incorporated in the reference documents, identified in this certificate. See Annex referred to the series of proving tests in accordance with:

IEC 60076-11 (2006)

This Type Test Certificate has been issued by CESI following conformity with the ITC-Code.

The results are shown in the record of Proving Tests and the intelligence attached in the Test Reports. The values obtained and the general performance are considered to comply with the above standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the Manufacturer.

Only original reproductions of this Certificate, or reproductions of this page accompanied by any pages in which are used the indicated ratings of the apparatus serial, are permitted without written permission from CESI.

No. of pages 3

CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY
 CESI S.p.A. - Milano - ITALY



CERTIFICATE



DQS GmbH
Deutsche Gesellschaft zur Zertifizierung von

hereby certifies that the company

Siemens AG
Energy Transmission Transformers (E T TR)
Katzwanger Str. 150
90461 Nürnberg
Hegelstraße 20
73230 Kirchheim

has implemented and maintains a **Quality, Environmental and Occupational Health and Safety Management System**

Scope:
Marketing, Sales, Design, Production and Testing and Service

Through an audit, documented in a report, it was found that the requirements of the following standards

ISO 9001 : 2008
ISO 14001 : 2004
BS OHSAS 18001 : 2007

Certificate registration no. 001052 QM08 UM B

Date of certification 2010-03-01

Valid until 2013-02-28

Michael Drechsel
Managing Director
August Schenk Straße 21, 60433 Frankfurt am Main



DET NORSKE VERIT MANAGEMENT SYSTEM CERTIFICATE

Certificate No.: 9804-2011-ARSO-GER-TG

This is to certify that

Siemens AG
Energy Sector
Division Power Transmission
Transformers E T TR
with the locations

Katzwanger Str. 150
90461 Nürnberg - Germany
Hegelstr. 20
73230 Kirchheim unter Teck - Germany

Siemens Transformers Austria GmbH & Co KG
Elingasse 3
K160 Weiz - Austria

has been found to conform to the Management System

ISO 9001:2008
ISO 14001:2004
BS OHSAS 18001:2007

This certificate is valid for the following product or service

**Marketing, Sales, Design, Production and Testing of
Transformers as well as for Commissioning**

Initial Certification date:

01.03.2010

This certificate is valid until:

28.02.2013

The audit has been performed under the supervision of

Britta Nockenberger Anandita
Lead Auditor

This certificate replaces the

To this certificate belongs the following

Lack of fulfillment of conditions or an audit
DNV Zertifizierung und Conformity Control, Schulweg 14



Certificate

Standard **BS OHSAS 18001:2007**

Certificate Registr. No. 01 113 060009

TÜV Rheinland Cert GmbH certifies:

Certificate Holder: **SIEMENS**

Siemens Zrt.
Transformer Division
1214 Budapest
E. Rákóczi Ferenc út 189.
Hungary

Scope: Design, production, servicing and sale of medium-voltage transformers and reactors

An audit was performed, Report No. 060509.
Proof has been furnished that the requirements according to BS OHSAS 18001:2007 are fulfilled.
The due date for all future audits is 20-04 (30.04.2011).

Validity: The certificate is valid from 2011-05-08 until 2014-05-07.

2011-05-08

Michael Drechsel
Managing Director



DGA-ZM-08-00-04

TÜV Rheinland®
Precisely Right.

Certificate

Standard **ISO 14001:2004**

Certificate Registr. No. 75 110 0151

TÜV Rheinland InterCert Kft. certifies:

Certificate Holder: **Siemens Transzformátor Kft.**
E. Rákóczi Ferenc utca 189.
H - 1214 Budapest
Hungary

Scope: design, production, servicing and sale of medium voltage transformers and reactors

An audit was performed. Proof has been furnished that the requirements according to ISO 14001:2004 are fulfilled.

Validity: The certificate is valid from 2011.01.25 until 2014.01.24.
First certification: 2002.

Budapest 2011-01-16

Michael Drechsel
Managing Director



TGA-ZM-09-00-00

TÜV Rheinland®
Precisely Right.

Certificate

Standard **ISO 9001:2008**

Certificate Registr. No. 75 100 9283

TÜV Rheinland InterCert Kft. certifies:

Certificate Holder: **Siemens Transzformátor Kft.**
E. Rákóczi Ferenc utca 189.
H - 1214 Budapest
Hungary

Scope: Design, production, servicing and sale of medium voltage transformers and reactors

An audit was performed. Proof has been furnished that the requirements according to ISO 9001:2008 are fulfilled.

Validity: The certificate is valid from 2009.12.28 until 2012.12.27.
First certification: 1996.

Budapest 2010-01-08

Michael Drechsel
Managing Director



TGA-ZM-09-00-00

TÜV Rheinland®
Precisely Right.

Published by and copyright © 2012:

Siemens AG
Energy Sector
Freyeslebenstrasse 1
91058 Erlangen, Germany

Transformatorenwerk Kirchheim
Hegelstrasse 20
73230 Kirchheim/Teck, Germany

Phone: +49 (0) 7021 508-0
Fax: +49 (0) 7021 508-495

Siemens Transzformátor Kft.
1214 Budapest
II. Rákóczi Ferenc u.189., Hungary
Phone: +36 (1) 278 5300
Fax: +36 (1) 278 5335

For more information, please contact
our Customer Support Center.
Phone: +49 180/524 70 00
Fax: +49 180/524 24 71
(Charges depending on provider)

E-mail: support.energy@siemens.com

Power Transmission Division
Order No. E50001-G640-A126-V1-7600 | Printed in Germany |
Dispo 19201 | c4bs No. 7481 |
TH 101-111120 | BR | 472661 | PA | 02121.0

Printed on elementary chlorine-free bleached paper.

All rights reserved.
Trademarks mentioned in this document are
the property of Siemens AG, its affiliates,
or their respective owners.

Subject to change without prior notice.

The information in this document contains
general descriptions of the technical options
available, which may not apply in all cases.
The required technical options should therefore
be specified in the contract.