






- NOTES**
- 1) TERMINALS RECOMMENDED ARE PRE-INSULATED & MUST BE CRIMPED USING APPROVED TOOLING. AMP PLOG OR PLASTI GRIP FUNNEL ENTRY (RING TONGUE) FOR M4 FIXING STUD.
 - 2) FOR OUTLINE & PANEL DRILLING, SEE 2995X10004 (A4).
 - 3) CONNECTIONS TO THIS COMMUNICATIONS FACILITY IS BY SCREENED, TWISTED PAIR CABLE ON SITE. WHEN WIRING OTHER FACILITIES ENSURE THAT THESE TERMINALS ARE NOT OBSCURED BY OTHER WIRE RUNS.
 - 4) CONTACTS SHOWN THUS  ARE INTERNAL RELAY CASE ASSEMBLY CONTACTS AND CLOSE WHEN THE RELAY CHASSIS IS WITHDRAWN FROM THE CASE.
 - 5) FOR THE RELAY CASE ASSEMBLY SEE 2436G40048

SUPPLIER	PART NUMBER	CABLE SIZE
AMP	342103	0.25-1.6mm ²
AMP	342143	1.0-2.6mm ²

OR ANY OTHER MANUFACTURERS EQUIVALENT TERMINAL

ABBREVIATIONS	
I-	CURRENT INPUTS
V-	VOLTAGE INPUTS
BI-	BINARY INPUTS
BO-	BINARY OUTPUTS
CO-	CHANGE-OVER BINARY OUTPUT CONTACTS
NO-	NORMALLY OPEN BINARY OUTPUT CONTACTS
NC-	NORMALLY CLOSED BINARY OUTPUT CONTACTS

COMMUNICATIONS IDENTIFICATION	
COM1	RS485 (ON BLOCK 'B' TERMINALS 14,16,18 & 20)
COM2	USB TYPE 'B' PORT (ON RELAY FRONT LABEL)



FOR INTERNAL USE ONLY
UNCONTROLLED COPY
NOT SUBJECT TO UPDATE

Rev	1A	Change	Change	Date	2008	Name	AMAR
DRAWING RELEASED		DRAWING RELEASED		2008		AMAR	
FINISH		FINISH		2008		AMAR	
MATERIAL		MATERIAL		2008		AMAR	
NTS		NTS		2008		AMAR	
Material		Material		2008		AMAR	
Title		Title		2008		AMAR	
TERMINAL ID & WIRING DIAGRAM FOR 7SR17		TERMINAL ID & WIRING DIAGRAM FOR 7SR17		2008		AMAR	
4CT+3VT+3BI+5BO(2CO+3NO),8 RTD		4CT+3VT+3BI+5BO(2CO+3NO),8 RTD		2008		AMAR	
Approved by		Approved by		2008		AMAR	
EM EA PRO R&D		EM EA PRO R&D		2008		AMAR	
Siemens Ltd		Siemens Ltd		2008		AMAR	
Document No		Document No		2008		AMAR	
2436W40065		2436W40065		2008		AMAR	
7SR17		7SR17		2008		AMAR	
1A		1A		2008		AMAR	
1 of 1		1 of 1		2008		AMAR	