



- Notes:**
- Main conduit box is free standing and must be supported from below by customer. Main conduit box is not level with motor feet. A removable bottom plate is supplied on the FS2 and FS3 conduit boxes. A 12.0" spacer is supplied on both frames for the FS2 and FS3 conduit boxes.
 - C = Length of motor from drive end of shaft to end of non-drive end of motor.
 - V = (N-W)-0.25" = length of shaft available for coupling.
 - Adding the low noise oversized side duct increases the spacer by 6.0" on both frames for the FS2 and FS3 conduit boxes. All associated conduit box dimensions will change accordingly.
 - 2 Pole machines may rotate in one direction only.
 - Shims may be necessary under motor feet for direct connection.
 - Rotor end float = 0.5"
 - End float of LEF coupling = 0.19"
 - Adding a rotating labyrinth seal to the drive end decreases N by: 2 Pole: 0.80" 4 Pole: 0.80"
 - When adding a ground brush, consult the factory. (BA and C will increase.)
 - For motors equipped with provisions for proximity probes use this print for our standard internal mounting.

Lubrication Per Bearing	
2 Pole	4 Pole
140-160 SUS @ 100°F	290-350 SUS @ 100°F
3.0 qt. capacity	3.0 qt. capacity

Standard Dimensions in Inches

Shaft	Frame	Speed	B	BA ₁₀	C _{2,10}	E	2F	K	N ₉	(N-W)	R	S	U	V ₃	ES	Approx. Ship Wt. (Lbs)
Short	6811	2 Pole	61.0	11.50	79.0	13.50	50.0	11.0	7.97	7.00	3.007	0.875	3.500	6.75	5.75	11200
Short	6811	4 Pole	61.0	11.50	81.3	13.50	50.0	11.0	10.22	9.25	4.169	1.250	4.875	9.00	8.00	12000
Short	6813	2 Pole	74.0	11.50	92.0	13.50	63.0	12.5	7.97	7.00	3.007	0.875	3.500	6.75	5.75	13900
Short	6813	4 Pole	74.0	11.50	94.3	13.50	63.0	12.5	10.22	9.25	4.169	1.250	4.875	9.00	8.00	14700

Certification: Customer _____ P.O. _____ S.O. _____ Item _____
 HP _____ RPM _____ Frame _____ PH/HZ/Volts 3/_____/_____
 By _____ Date _____ Terminal Box Size FS2 FS3

Comments _____
 Not for construction, installation or application purposes unless certified.