



LOCATION DIMENSIONS

BOM.NO.	"A"	"B"	"C"
-01	3.75	0.63	1.25
-03			
-02	6.25	1.88	2.50
-04			

TORQUE VALUES

10 — 50 in-lbs. AL. / 72 in-lbs. CU.

11 — 30 in-lbs. AL. / 50 in-lbs. CU.

⚠ DANGER

Hazardous voltage.
Will cause death or serious injury.

Keep out.
Qualified personnel only.
Disconnect and lock off all power before working on this equipment.

E-2-4-& 6 FRAME BRANCH BREAKER
15-125 AMPERE
DOUBLE MOUNTING

FOR I.T.E. TYPE BREAKERS:
E2, E4, E6, HE4, HE6
E2-A, E4-A, E6-A, HE4-A, HE6-A
E2, ED4, ED6, HED4, HED6

10	1C-381A 8-30-00								
9	1C-267A 1-15-00								
8	1B-908 4-20-95								
7	8A093 7-14-88								
6	CN:622								
5	CN:557								
4	CN554								
3	CN:440								
2	CN:416								

Third Angle Proj

Dwg. No. 11-5079-00 | Sht 1 | Rev 10

Rev	C.N.	Date
1	CN:319	
0	272	4-19-82

Unless otherwise specified dimensions are in inches

Tolerances are non-cumulative and are as follows unless specified otherwise.

.XX ± .030
.XXX ± .015
Angular ± 2°

Do not scale drawing

Confidential – Property of
Siemens Industry, Inc.
Building Technologies Division

ED2, ED4, & ED6 MOUNTING
SERIES 6 BRANCH BUS

Dwn DB	Date 1-11-00	Dwg No. 11-5079-00 Rev. 10
Chk RHR	Date 1-11-00	
Apvd RHR	Date 1-4-00	Scale NONE Sheet 1 of 1

Apvd	ITEM	DESCRIPTION	PC. NO.	QTY.
SH 5-17-95	1	E2-4-6 PHASE AC BRANCH BUS	11-7140-01	2
	2	E2-4-6 PHASE B BRANCH BUS	11-7141-01	1
	3	E2-4-6 LINE CONNECTOR	11-7138-01	3
	4	INTERPHASE BARRIER	15-7505-01	2
	5	E2-4-6 MOUNTING BRACKET	15-B-3014-02	2
	6	3.750 E2-4-6 COVER PLATE	12-6024-01	1
	7	CIRCUIT I.D. CARD	11-7505-01	2
	8	CARD HOLDER	11-7506-01	2
	9	1/4-20 X 3/8 SHWHSW	11-1553-02	2
	▲ 10	STRAP-BUS HARDWARE KIT	11-B-2022-05	1
	11	10-24 X 5/8 ISHOWHSW	11-1576-07	12
	12			
	13	1/4-20 X 5/8 SHWHSW	11-1553-06	8
	14	NEUTRAL LUG ASSEMBLY	12-B-2105-01	1
	15			
	16	BLANK FILLER	12-5531-09	2
	17			
	18			
	19			
	20			
	21			
	22			
	23			
	24			
	25			
	26			
	27			
	28	INSTRUCTION SHEET	31-1215-01	1
	29	CARTON LABEL	15-A-1027-01	1
	30	CARTON	48001056	1
	31			
	32			
	33			
	34	ED FRAME BRANCH BREAKER		
	35	15-125 AMPHERE		
	36			
	37	FOR BREAKER TYPES: ▲		
	38	E2, E4, E6, HE4, HE6		
	39	E2-A, E4-A, E6-A, HE4-A, HE6-A		
	40	ED2, ED4, ED6, HED4, HED6		
	41			
	42			
	43			
	44	MERCHANDISE KIT NO. SE6D		

Revisions
0: 1B-908 4:1C-381A 8-30-00
1: 1C-155B 08-13-97 5:1C-831A 4-12-04
2: 1C-206 01-26-98 6:1C-831B 7-25-06
3: 1C-267A 1-7-00 7:1E-166B 12-11-09

Chk SH 5-17-95

By RAW 5-17-95

Confidential – property of
Siemens Industry, Inc.
Norcross, GA
Building Technologies Division

ED2-4-6 MOUNTING, S5 COPPER BRANCH BUS
Title

11-5079-06 Dwg No.
Sht. 1 Of 1

7 Rev.

FOR USE WITH ED2, ED4, ED6, HED4 AND HED6 FRAME BREAKERS MOUNTED IN SPP/FPP/S5/F2/P5 PANELBOARDS (DEEP BOX).

Siemens Industry, Inc.
Building Technologies Division
Norcross, GA

CAT. NO. **SE6D**