



SIEMENS

Ingenuity for life

Cutting pump operation energy costs with ultrasonic controller

What energy-saving practices do you perform at home? Turning off the lights when leaving a room, replacing drafty windows for energy-efficient ones, running your dishwasher at times when electricity is less expensive?

These are great practices and are sure to save you money each month. But what about creating energy cost savings in the millions of dollars? Siemens SITRANS LUT400 ultrasonic controller, helps wastewater treatment facilities save significant amounts of money each year.

For a water/wastewater treatment plant (W/WWTP), pumping is one of the most expensive parts of day-to-day operations. Varying from country to country, these costs range from 30 to 50 percent or more of a W/WWTP's hydro bills – and in the future, this number will only increase as energy prices climb. Overall, water and wastewater treatment are one of the largest energy consumers in most

municipalities, so any savings have an impact on more than just the W/WWTP.

By the numbers

Just how much does pumping cost? Take your average 50 horsepower pump. In an hour, this pump consumes around 37 kilowatts. Do the math and at a cost of \$0.065 per kilowatt hour (kWh) – Ontario, Canada's off-peak price – that one pump costs a W/WWTP \$12 every day, \$4400 each year (as it has a running time of five hours per day).

But we know that many places, including Canada, the UK, Germany, South Africa, and Australia, have different rates according to the time of day or season

usa.siemens.com/level

energy is consumed. So while our single pump costs \$0.065 per hour during low-energy periods, it now costs up to 80% more during Ontario's peak-energy periods. So if the same company did all of its pumping during these peak periods, over the course of a year it would have spent an additional \$3500! And remember this is just for a single pump – many W/WWTPs have hundreds of pumps, depending on a facility's size.

Of course, no company is going to pump only in peak-energy periods – as we have just seen, that would be outrageously expensive. But, since wastewater treatment happens at all times of the day, facilities must pump during these high-cost periods.

So, how do I save money?

SITRANS LUT400 ultrasonic controller, features two models that control economy-pumping regimes (also known as skimming): SITRANS LUT430 Level, Volume, Pump, and Flow Controller; and SITRANS LUT440 High Accuracy Open Channel Monitor, providing a full suite of advanced level, volume, and pump controls.

In normal operation, the controller will turn on pumps once water reaches the high level set point and then will begin pumping down to the low level set point. In economy pumping, the controller will pump wells down to their lowest level before the premium rate period starts, thereby maximizing the well's storage capacity. The controller then maintains a higher level during the tariff period by using the storage capacity of the collection network. Pumping in this way ensures compliance with environmental regulations and minimizes energy use in peak tariff periods.

How do I set up an economy-pumping regime?

Install SITRANS LUT400 ultrasonic controller and connect it to a Siemens Echomax transducer in your well. You will set pump on and off points based on your local peak-energy periods. During summer in Ontario, for example, the peak tariff period is between 11 a.m. and 5 p.m. In the winter, these times change to 7-11 a.m. and 5-7 p.m. You can program up to five peak zones during one 24-hour period.

To begin setting up your economy-pumping regime, enable SITRANS LUT400's Energy Savings function. Set the Peak Lead Time to 60 minutes to start pumping water down 60 minutes before the high-cost period begins so the well is at its lowest point. Depending on the volume of your well, you can set your Peak Lead Time to any amount between zero and 65,535 minutes.

On the controller, select the Peak Start Time of 11:00 a.m. and the Peak End Time of 5:00 p.m. Set your Peak ON Setpoint to nine meters and the Peak OFF Setpoint to six meters, as shown in Figure 1.

In Normal Operation mode, the controller starts the pump when water reaches eight meters and stops the pump at two meters. In Energy Saving mode, SITRANS LUT400 turns on the pump when water reaches nine meters and stops pumping at six meters, thus running the pump for the minimum amount of time during peak tariff periods. Cost-savings through economy-pumping regimes are simple to put in place with these steps.

Don't forget that when you are setting up your controller, you can take advantage of SITRANS LUT400's real-time clock for daylight saving time adjustment. The real-time clock is a useful feature – input your location's daylight saving time and economy pumping will occur throughout the year without interruption.




Figure 1: During peak periods, the pump operating range is much smaller than in normal operation, reducing the amount of time pumps must run.

Siemens Echomax transducers installed in the well and the SITRANS LUT400 controller measure the level of water and control pump operations.



Setting up an economy-pumping regime and performing infiltration and ingress monitoring is simple and can cut your company's energy costs dramatically.

Infiltration and ingress (I&I) monitoring

Another cost-saving feature of this controller is infiltration and ingress monitoring with SITRANS LUT400's pumped volume feature and built-in datalogging capabilities.

In a closed collection network, it is inefficient and costly to pump rainwater entering the system due to leakages from degraded pipes. SITRANS LUT400 calculates pumped volumes, providing useful historical trending information for detecting abnormal increases of pumped water.

To use this feature, provide the known volume in the well between the pump's ON and OFF setpoints. The controller will calculate the pumped volume based on the rate of level change in the well during pumping. It also calculates the inflow rate based on the rate of level change in the well just prior to pump startup.



LUT400 controller and XRS-5 transducer in a wet well application.

SITRANS LUT400 logs this information for you to review via the controller's communications options, or by connecting a USB cable and downloading logs directly to your computer. By comparing these results, you can see if inflow rates are greater due to rainwater entering the system. Repair those damaged pipes and the cost savings begin!

Through economy pumping and I&I monitoring, SITRANS LUT400 gives companies the potential for significant energy savings. One SITRANS LUT400 user stated that every small change his company makes to reduce consumption has the potential to save millions of dollars each year.



**Measuring everything that matters:
usa.siemens.com/pi**

**Siemens Process Instrumentation offers
best-in-class measurement and seamless
integration into your automation system.
We are the total solution provider for flow,
level, pressure, temperature, weighing,
positioners and more.**

Follow us on:

www.facebook.com/siemensii

<https://twitter.com/siemensii>

www.youtube.com/siemens

<https://blogs.siemens.com/measuringsuccess>



Siemens Industry, Inc.
Process Industries and Drives
100 Technology Drive
Alpharetta, GA 30005
1-800-365-8766
info.us@siemens.com

Subject to change without prior notice

Order No.: PIBR-00032-0418

All rights reserved

Printed in USA

© 2018 Siemens Industry, Inc.

Subject to changes and errors. The information given in this document only contains general descriptions and/or performance features which may not always specifically reflect those described, or which may undergo modification in the course of further development of the products. The requested performance features are binding only when they are expressly agreed upon in the concluded contract.

All product designations may be registered trademarks of Siemens AG. All other designations in this document may represent trademarks whose use by third parties for their own purposes may violate the proprietary rights of the owner.