



# Certificate of Compliance

**Certificate:** 1452663 (LR24563-13)

**Master Contract:** 154852

**Project:** 1452663

**Date Issued:** 2004/03/29

**Issued to:** Siemens Energy & Automation, Inc.

811 N Main St  
Bellefontaine, Ohio 43311  
USA

**Attention:** Branson Redding

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Charles Law

**Authorized by:** Nick Alfano, Operations  
Manager

## **PRODUCTS**

**CLASS 4652 04** - SWITCHES - Miscellaneous

Switches, fused, miscellaneous, Cat. No. HCP367, HCP368, HCP327 and HCP328, 3-pole, 1200A max, 600V ac max, 500 hp max.

Switches, fused, miscellaneous, Cat. No. V7F3644, 3-pole, 200A, 600V ac max.

## **APPLICABLE REQUIREMENTS**

CAN/CSA C22.2 No. 4-M89 - Enclosed Switches