# ECQTH2



### Handle Tie Device

#### Same As:

- QTH2
- BX150HTU
- BX150HT

Package contains 25 devices.



#### 407030434700

#### INSTALLATION INSTRUCTIONS



# **A** DANGER

Hazardous Voltage. Will cause death, serious injury or substantial property damage.

Turn off power supplying this equipment before working inside.

## **▲** SAFETY INSTRUCTIONS

Note: This instruction outlines the recommended installation procedure.

- 1. Turn both circuit breakers to "OFF" position.
- 2. Remove circuit breakers from panel, if previously installed.
- Insert ends of handle tie into handle holes.
- 4. Install circuit breakers into panel, with handles in the "OFF" position.

2007 Cop vright Siemen's Industry, Inc.

600662A Rev.X

Siemens Industry, Inc.

Norcross, Georgia U.S.A.

Assembled in Mexico